



July 2009

**TRANSFIELD SERVICES PTY. LTD.,  
RINGWOOD, VICTORIA**

# **EastLink Ventilation Stack Emission Monitoring Report April - June 2009**

**Submitted to:**  
Transfield Services Pty. Ltd.



This document is issued in accordance with NATA's accreditation requirements.

Accredited for compliance with ISO/IEC 17025.

The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards.

REPORT

**Report Number:** 097613024 007 Rev 0

**Distribution:**

1 Copy - Transfield Services Pty. Ltd.

1 Copy - Golder Associates Pty. Ltd.



**A world of  
capabilities  
delivered locally**





## Record of Issue

Company	Client Contact	Version	Date Issued	Method of Delivery
Transfield Services Pty. Ltd., EastLink Operations Centre, 2 Hillcrest Avenue, Ringwood, 3134	Ms. Marielle Bright	Revision 0	09/07/2009	Post



## Table of Contents

<b>1.0 INTRODUCTION</b> .....	<b>1</b>
<b>2.0 DISCHARGES TO AIR</b> .....	<b>2 - 3</b>
<b>3.0 VENTILATION STACK MONITORING PARAMETERS</b> .....	<b>3</b>
<b>4.0 METHODS</b> .....	<b>4 - 5</b>
4.1 PM <sub>2.5</sub> .....	4
4.2 PM <sub>10</sub> .....	4
4.3 Carbon Monoxide.....	4
4.4 Oxides of Nitrogen .....	5
4.5 Stack Velocity .....	5
<b>5.0 MEASUREMENT UNCERTAINTY</b> .....	<b>6</b>
<b>6.0 VENTILATION STACK EMISSION MONITORING PERIOD: 01/04/2009 – 30/06/2009</b> .....	<b>7 - 14</b>
6.1 Data Capture.....	7
6.2 Results .....	8
<b>6.2.1</b> PM <sub>2.5</sub> .....	<b>8</b>
6.2.2 PM <sub>10</sub> .....	9
6.2.3 Carbon Monoxide .....	10
6.2.4 Oxides of Nitrogen.....	11
6.2.4.1 Nitric Oxide .....	11
6.2.4.2 Nitrogen Dioxide .....	12
6.2.5 Stack Velocity .....	13
6.3 Data Validation and Exception .....	14
<b>7.0 VENTILATION STACK EMISSION MONITORING PERIOD: 01/05/2009 – 31/05/2009</b> .....	<b>15 - 22</b>
7.1 Data Capture.....	15
7.2 Results .....	16
7.2.1 PM <sub>2.5</sub> .....	16
7.2.2 PM <sub>10</sub> .....	17
7.2.3 Carbon Monoxide .....	18
7.2.4 Oxides of Nitrogen.....	19
7.2.4.1 Nitric Oxide .....	19
7.2.4.2 Nitrogen Dioxide .....	20



## Table of Contents

7.2.5	Stack Velocity .....	21
7.3	Data Validation and Exception .....	22
<b>8.0</b>	<b>VENTILATION STACK EMISSION MONITORING PERIOD: 01/06/2009 – 30/06/2009 .....</b>	<b>23 - 30</b>
8.1	Data Capture.....	23
8.2	Results .....	24
8.2.1	PM <sub>2.5</sub> .....	24
8.2.2	PM <sub>10</sub> .....	25
8.2.3	Carbon Monoxide .....	26
8.2.4	Oxides of Nitrogen.....	27
8.2.4.1	Nitric Oxide .....	27
8.2.4.2	Nitrogen Dioxide .....	28
8.2.5	Stack Velocity .....	29
8.3	Data Validation and Exception .....	30
<b>9.0</b>	<b>DISCUSSION .....</b>	<b>31</b>
9.1	Comparison with Licence Limits.....	31

### TABLES

Table 1:	Discharges to Air .....	2
Table 2:	Measurement Uncertainty.....	6
Table 3:	Data Capture Statistics - 1 Hour Averages .....	7
Table 4:	PM <sub>2.5</sub> Mass Rate Percentiles (1 Hour Average) .....	8
Table 5:	PM <sub>10</sub> Mass Rate Percentiles (1 Hour Average) .....	9
Table 6:	Carbon Monoxide Mass Rate Percentiles (1 Hour Average) .....	10
Table 7:	Nitric Oxide Mass Rate Percentile (1 Hour Average).....	11
Table 8:	Nitrogen Dioxide Mass Rate Percentiles (1 Hour Average) .....	12
Table 9:	Data Exceptions - Eastern Ventilation Stack: April 2009 .....	14
Table 10:	Data Exceptions - Western Ventilation Stack: April 2009 .....	14
Table 11:	Data Capture Statistics - 1 Hour Averages .....	15
Table 12:	PM <sub>2.5</sub> Mass Rate Percentiles (1 Hour Average) .....	16
Table 13:	PM <sub>10</sub> Mass Rate Percentiles (1 Hour Average) .....	17
Table 14:	Carbon Monoxide Mass Rate Percentiles (1 Hour Average) .....	18
Table 15:	Nitric Oxide Mass Rate Percentiles (1 Hour Average) .....	19



## Table of Contents

Table 16: Nitrogen Dioxide Mass Rate Percentiles (1 Hour Average) .....	20
Table 17: Data Exceptions - Eastern Ventilation Stack: May 2009.....	22
Table 18: Data Exceptions - Western Ventilation Stack: May 2009.....	22
Table 19: Data Capture Statistics - 1 Hour Averages .....	23
Table 20: PM <sub>2.5</sub> Mass Rate Percentiles (1 Hour Average) .....	24
Table 21: PM <sub>10</sub> Mass Rate Percentiles (1 Hour Average) .....	25
Table 22: Carbon Monoxide Mass Rate Percentiles (1 Hour Average) .....	26
Table 23: Nitric Oxide Mass Rate Percentiles (1 Hour Average).....	27
Table 24: Nitrogen Dioxide Mass Rate Percentiles (1 Hour Average) .....	28
Table 25: Data Exceptions - Eastern Ventilation Stack: June 2009.....	30
Table 26: Data Exceptions - Western Ventilation Stack: June 2009.....	30
Table 27: Maximum (1 Hour Average) Mass Rate (01/01/2009 - 30/06/2009) .....	31
Table 28: Data Capture Year to Date .....	31

### FIGURES

Figure 1: Ventilation Stack Locations .....	2
Figure 2: PM <sub>2.5</sub> Mass Rate (1 Hour Average).....	8
Figure 3: PM <sub>10</sub> Mass Rate (1 Hour Average) .....	9
Figure 4: Carbon Monoxide Mass Rate (1 Hour Average).....	10
Figure 5: Nitric Oxide Mass Rate (1 Hour Average) .....	11
Figure 6: Nitrogen Dioxide Mass Rate (1 Hour Average) .....	12
Figure 7: Stack Velocity (1 Hour Average) .....	13
Figure 8: PM <sub>2.5</sub> Mass Rate (1 Hour Average) .....	16
Figure 9: PM <sub>10</sub> Mass Rate (1 Hour Average).....	17
Figure 10: Carbon Monoxide Mass Rate (1 Hour Average).....	18
Figure 11: Nitric Oxide Mass Rate (1 Hour Average) .....	19
Figure 12: Nitrogen Dioxide Mass Rate (1 Hour Average) .....	20
Figure 13: Stack Velocity (1 Hour Average).....	21
Figure 14: PM <sub>2.5</sub> Mass Rate (1 Hour Average).....	24
Figure 15: PM <sub>10</sub> Mass Rate (1 Hour Average) .....	25
Figure 16: Carbon Monoxide Mass Rate (1 Hour Average).....	26



## Table of Contents

Figure 17: Nitric Oxide Mass Rate (1 Hour Average) .....	27
Figure 18: Nitrogen Dioxide Mass Rate (1 Hour Average) .....	28
Figure 19: Stack Velocity (1 Hour Average).....	29

### APPENDICES

#### APPENDIX A Limitations



## **1.0 INTRODUCTION**

EastLink is a 39-kilometre motorway running between Donvale in Melbourne's north east to Frankston in Melbourne's south east with two tunnels under the Mullum Mullum Valley. Transfield Services, who are responsible for operation and maintenance of the road, commissioned Golder Associates Pty. Ltd. {trading as A.W.N. (Air Water Noise) Consultants} to provide continuous emission monitoring services for the EastLink Road project. The services provided include:

- Operations and maintenance services for the EastLink ventilation stack continuous emission monitoring systems (CEMS);
- NATA endorsed emission monitoring reports.

Monitoring commenced on the 29<sup>th</sup> June, 2008 with the opening of the EastLink motorway. Results for the sampling period 1<sup>st</sup> April, 2009 to 30<sup>th</sup> June, 2009 inclusive are contained in the following report.

Your attention is drawn to the document - "Limitations", which is included in Attachment A of this report. The statements presented in this document are intended to advise you of what your realistic expectations of this report should be. The document is not intended to reduce the level of responsibility accepted by Golder, but rather to ensure that all parties who may rely on this report are aware of the responsibilities each assumes in so doing.



## 2.0 DISCHARGES TO AIR

EastLink has discharges to air servicing two road tunnels. Discharge Point No. 1 (DP1) services the inbound (Melba) tunnel and Discharge Point No. 2 (DP2) services the outbound (Mullum Mullum) tunnel.

The locations of the discharges to air are described in Table 1 and presented in Figure 1.

**Table 1: Discharges to Air**

Discharge Point No.	Station Name	Location
1	Western ventilation stack	Western end of inbound tunnel (Melba) - Donvale
2	Eastern ventilation stack	Eastern end outbound tunnel (Mullum Mullum) – Ringwood

Monitoring equipment is housed in temperature controlled cabinets located at the base of each of the ventilation stacks. Particulate and gaseous sample inlets are installed inside the plenum chamber of each of the ventilation stacks.



*Figure 1: Ventilation Stack Locations*



### **3.0 VENTILATION STACK MONITORING PARAMETERS**

The following parameters are monitored continuously, with averages logged at 5 minute intervals.

- Particulate matter with an equivalent aerodynamic diameter less than 2.5 microns (PM<sub>2.5</sub>);
- Particulate matter with an equivalent aerodynamic diameter less than 10 microns (PM<sub>10</sub>);
- Total oxides of nitrogen (NO<sub>x</sub>);
- Nitric oxide (NO);
- Nitrogen dioxide (NO<sub>2</sub>);
- Carbon monoxide (CO);
- Stack velocity;
- Stack temperature and
- Ambient pressure.



## **4.0 METHODS**

### **4.1 PM<sub>2.5</sub>**

PM<sub>2.5</sub> concentrations in the tunnel ventilation stacks are determined using a 1400 Series Tapered Element Oscillating Microbalance (TEOM) analyser, located in the plenum chamber of the ventilation stacks.

Exhaust gas is drawn through a PM<sub>2.5</sub> size selective inlet (PM<sub>10</sub> WINS head fitted with a PM<sub>2.5</sub> sharp cut cyclone (SCC)) at 1 m<sup>3</sup>/h. The flow is then isokinetically split into two streams; 1 l/min stream which passes through the filter on the mass transducer and a 15.7 l/min bypass stream.

The sample stream is heated to 50°C to maintain a low and therefore relatively constant humidity.

Measurements are made in real-time (2 s intervals) with the 5-minute averages logged. 1-hour averages are then calculated from the logged data.

The PM<sub>2.5</sub> monitoring method is based on the requirements of Australian Standard AS 3580.9.8, *“Methods for Sampling and Analysis of Ambient Air: Determination of Suspended Particulate Matter – PM<sub>10</sub> Continuous Direct Mass Method Using a Tapered Element Oscillating Microbalance Analyser”*.

### **4.2 PM<sub>10</sub>**

PM<sub>10</sub> concentrations in the tunnel ventilation stacks are determined using a 1400 Series Tapered Element Oscillating Microbalance (TEOM) analyser, located in the plenum chamber of the ventilation stacks.

Exhaust gas is drawn through a PM<sub>10</sub> size selective inlet (PM<sub>10</sub> WINS head) at 1 m<sup>3</sup>/h. The flow is then isokinetically split into two streams; 1 l/min stream which passes through the filter on the mass transducer and a 15.7 l/min bypass stream.

The sample stream is heated to 50°C to maintain a low and therefore relatively constant humidity.

Measurements are made in real-time (2 s intervals) with the 5-minute averages logged. 1-hour averages are then calculated from the logged data.

The PM<sub>10</sub> monitoring method is based on the requirements of Australian Standard AS 3580.9.8, *“Methods for Sampling and Analysis of Ambient Air: Determination of Suspended Particulate Matter – PM<sub>10</sub> Continuous Direct Mass Method Using a Tapered Element Oscillating Microbalance Analyser”*.

### **4.3 Carbon Monoxide**

Carbon monoxide concentrations in the tunnel ventilation stacks are determined by infra-red gas filter correlation analysers.

Automatic calibrations are carried out daily against a NATA certified reference gas mixture. Manual calibrations are conducted at one month intervals.

The carbon monoxide monitoring method is based on the requirements of Australian Standard AS 3580.7.1-1992, *“Determination of Carbon Monoxide – Direct Reading Instrumental Method”*.



#### **4.4 Oxides of Nitrogen**

Oxides of nitrogen concentrations in the tunnel ventilation stacks are determined by chemiluminescence gas analysers.

Automatic calibrations are carried out daily against a NATA certified reference gas mixture. Manual calibrations are conducted at one month intervals.

The oxides of nitrogen (NO, NO<sub>2</sub> and NO<sub>x</sub>) monitoring method is based on the requirements of Australian Standard AS 3580.5.1-1993, *"Determination of Oxides of Nitrogen – Chemiluminescence Method"*.

#### **4.5 Stack Velocity**

Stack gas velocity was determined using an optical flow sensor that complies with USEPA Code of Federal Regulations (CFR 40) Part 75, *"Continuous Emission Monitoring"* requirements.



## 5.0 MEASUREMENT UNCERTAINTY

**Table 2: Measurement Uncertainty**

Parameter	Method	Estimated Uncertainty
PM <sub>10</sub>	TEOM	± 5%
PM <sub>2.5</sub>	TEOM	± 5%
NO, NO <sub>2</sub> , NO <sub>x</sub>	Chemiluminescence	± 10%
CO	Infra-red gas filter correlation	± 10%
Stack velocity	Optical flow sensor	± 0.1 m/s or 5% of reading, whichever is greater



## **6.0 VENTILATION STACK EMISSION MONITORING PERIOD: 01/04/2009 – 30/04/2009**

### **6.1 Data Capture**

Data capture is defined as the number of valid data periods collected divided by the number of available data periods. Valid data excludes periods where the instrument is unavailable due to calibration and maintenance and excludes periods where the data has been rejected due to quality assurance/data validation procedures.

The data capture statistics for the reporting period 1<sup>st</sup> April to 30<sup>th</sup> April, 2009 are shown in Table 3. Averages were only collected for those periods where the 5-minute data constituted 75% data capture.

Section 6.3 provides further information on the reasons for invalid data periods.

**Table 3: Data Capture Statistics - 1 Hour Averages**

<b>Parameter</b>	<b>Station</b>	<b>Collected Periods</b>	<b>Available Periods</b>	<b>Data Capture</b>
PM <sub>2.5</sub>	Eastern	717	720	99.6%
	Western	718	720	99.7%
PM <sub>10</sub>	Eastern	718	720	99.7%
	Western	717	720	99.6%
NO, NO <sub>2</sub>	Eastern	632	720	87.8%
	Western	688	720	95.6%
CO	Eastern	688	720	95.6%
	Western	688	720	95.6%



## 6.2 Results


### 6.2.1 PM<sub>2.5</sub>

PM<sub>2.5</sub> was continuously monitored and 5 minute averages logged. The 5 minute average data was then transformed to 1 hour averages for reporting.

PM<sub>2.5</sub> (1 hour average) mass rate of emission statistics for the reporting period are given in Table 4. A plot of PM<sub>2.5</sub> (1 hour average) mass rate of emission for the reporting period is presented in Figure 2.

**Table 4: PM<sub>2.5</sub> Mass Rate Percentiles (1 Hour Average)**

Station	PM <sub>2.5</sub> Mass Rate (kg/h) (1-Hour Average)						
	Maximum	99 <sup>th</sup>	98 <sup>th</sup>	95 <sup>th</sup>	90 <sup>th</sup>	75 <sup>th</sup>	50 <sup>th</sup>
Eastern	0.39	0.23	0.20	0.18	0.15	0.12	0.04
Western	0.38	0.28	0.24	0.20	0.17	0.11	0.05



*Figure 2: PM<sub>2.5</sub> Mass Rate (1 Hour Average)*



# EASTLINK VENTILATION STACK EMISSION MONITORING REPORT: APRIL - JUNE 2009


## 6.2.2 PM<sub>10</sub>

PM<sub>10</sub> was continuously monitored and 5 minute averages logged. The 5 minute average data was then transformed to 1 hour averages for reporting.

PM<sub>10</sub> (1 hour average) mass rate of emission statistics for the reporting period are given in Table 5. A plot of PM<sub>10</sub> (1 hour average) mass rate of emission for the reporting period is presented in Figure 3.

**Table 5: PM<sub>10</sub> Mass Rate Percentiles (1 Hour Average)**

Station	PM <sub>10</sub> Mass Rate (kg/h) (1-Hour Average)						
	Maximum	99 <sup>th</sup>	98 <sup>th</sup>	95 <sup>th</sup>	90 <sup>th</sup>	75 <sup>th</sup>	50 <sup>th</sup>
Eastern	0.52	0.31	0.29	0.25	0.21	0.16	0.06
Western	0.84	0.40	0.32	0.25	0.21	0.14	0.06



*Figure 3: PM<sub>10</sub> Mass Rate (1 Hour Average)*




### 6.2.3 Carbon Monoxide

Carbon monoxide (1 hour average) mass rate of emission statistics for the reporting period are given in Table 6. A plot of carbon monoxide (1 hour average) mass rate for the reporting period is presented in Figure 4.

**Table 6: Carbon Monoxide Mass Rate Percentiles (1 Hour Average)**

Station	Carbon Monoxide Mass Rate (kg/h) (1-Hour Average)						
	Maximum	99 <sup>th</sup>	98 <sup>th</sup>	95 <sup>th</sup>	90 <sup>th</sup>	75 <sup>th</sup>	50 <sup>th</sup>
Eastern	31	22	21	19	15	10	7.3
Western	30	29	25	18	15	11	7.6



*Figure 4: Carbon Monoxide Mass Rate (1 Hour Average)*




## 6.2.4 Oxides of Nitrogen

### 6.2.4.1 Nitric Oxide

Nitric oxide (1 hour average) mass rate of emission statistics for the reporting period are given in Table 7. A plot of nitric oxide (1 hour average) mass rate for the reporting period is presented in Figure 5.

**Table 7: Nitric Oxide Mass Rate Percentile (1 Hour Average)**

Station	Nitric Oxide Concentration (ppm) (1-Hour Average)						
	Maximum	99 <sup>th</sup>	98 <sup>th</sup>	95 <sup>th</sup>	90 <sup>th</sup>	75 <sup>th</sup>	50 <sup>th</sup>
Eastern	4.8	3.7	3.5	3.2	2.7	2.2	1.1
Western	11	11	10	7.1	6.5	5.2	2.7



*Figure 5: Nitric Oxide Mass Rate (1 Hour Average)*




**6.2.4.2 Nitrogen Dioxide**

Nitrogen dioxide (1 hour average) mass rate of emission statistics for the reporting period are given in Table 8. A plot of nitrogen dioxide (1 hour average) mass rate for the reporting period is presented in Figure 6.

**Table 8: Nitrogen Dioxide Mass Rate Percentiles (1 Hour Average)**

Station	Nitrogen Dioxide Mass Rate (kg/h) (1-Hour Average)						
	Maximum	99 <sup>th</sup>	98 <sup>th</sup>	95 <sup>th</sup>	90 <sup>th</sup>	75 <sup>th</sup>	50 <sup>th</sup>
Eastern	0.7	0.4	0.3	0.3	0.2	0.2	0.1
Western	1.1	1.0	0.9	0.8	0.7	0.6	0.3



*Figure 6: Nitrogen Dioxide Mass Rate (1 Hour Average)*



## 6.2.5 Stack Velocity

The stack velocity (1 hour average) plot for the reporting period is presented in Figure 7.




Figure 7: Stack Velocity (1 Hour Average)



### 6.3 Data Validation and Exception

Data contained in the report has been validated against performance and calibration requirements for each instrument. Data during maintenance and calibration periods has been removed from the validated data sets. Tables 9 and 10 list the data exceptions for the eastern and western ventilation stacks respectively. Data during automatic calibrations of the gaseous atmospheric contaminants has also been removed from the data sets.

**Table 9: Data Exceptions - Eastern Ventilation Stack: April 2009**

Eastern Ventilation Stack			
Start	End	Parameter	Reason
1/04/2009 3:00	1/04/2009 14:00	NO, NO <sub>2</sub> , NO <sub>x</sub>	Invalid data - span drift
1/04/2009 14:10	1/04/2009 15:15	NO, NO <sub>2</sub> , NO <sub>x</sub>	Maintenance/calibration
3/04/2009 10:05	3/04/2009 11:20	NO, NO <sub>2</sub> , NO <sub>x</sub>	Maintenance/calibration
9/04/2009 9:35	9/04/2009 10:30	NO, NO <sub>2</sub> , NO <sub>x</sub>	Maintenance/calibration
9/04/2009 9:35	9/04/2009 11:15	PM <sub>10</sub> , PM <sub>2.5</sub>	Maintenance/calibration
15/04/2009 3:00	16/04/2009 13:30	NO, NO <sub>2</sub> , NO <sub>x</sub>	Invalid data - span drift
16/04/2009 13:40	16/04/2009 14:40	NO, NO <sub>2</sub> , NO <sub>x</sub>	Maintenance/calibration
22/04/2009 13:15	22/04/2009 13:45	NO, NO <sub>2</sub> , NO <sub>x</sub>	Maintenance/calibration
30/04/2009 10:45	30/04/2009 12:00	NO, NO <sub>2</sub> , NO <sub>x</sub>	Maintenance/calibration

**Table 10: Data Exceptions - Western Ventilation Stack: April 2009**

Western Ventilation Stack			
Start	End	Parameter	Reason
5/04/2009 13:20	5/04/2009 14:10	NO, NO <sub>2</sub> , NO <sub>x</sub> , CO	Maintenance/calibration
5/04/2009 13:20	5/04/2009 14:10	PM <sub>2.5</sub>	Maintenance/calibration
7/04/2009 17:50	7/04/2009 18:25	PM <sub>10</sub>	Unrealistic data
9/04/2009 13:25	9/04/2009 14:50	PM <sub>10</sub>	Maintenance/calibration
9/04/2009 13:40	9/04/2009 14:05	NO, NO <sub>2</sub> , NO <sub>x</sub> , CO	Maintenance/calibration



## **7.0 VENTILATION STACK EMISSION MONITORING PERIOD: 01/05/2009 – 31/05/2009**

### **7.1 Data Capture**

Data capture is defined as the number of valid data periods collected divided by the number of available data periods. Valid data excludes periods where the instrument is unavailable due to calibration and maintenance and excludes periods where the data has been rejected due to quality assurance/data validation procedures.

The data capture statistics for the reporting period 1<sup>st</sup> May to 31<sup>st</sup> May, 2009 are shown in Table 11. Averages were only collected for those periods where the 5-minute data constituted 75% data capture.

Section 7.3 provides further information on the reasons for invalid data periods.

**Table 11: Data Capture Statistics - 1 Hour Averages**

<b>Parameter</b>	<b>Station</b>	<b>Collected Periods</b>	<b>Available Periods</b>	<b>Data Capture</b>
PM <sub>2.5</sub>	Eastern	740	744	99.5%
	Western	740	744	99.5%
PM <sub>10</sub>	Eastern	740	744	99.5%
	Western	742	744	99.7%
NO, NO <sub>2</sub>	Eastern	710	744	95.4%
	Western	710	744	95.4%
CO	Eastern	710	744	95.4%
	Western	709	744	95.3%



## 7.2 Results


### 7.2.1 PM<sub>2.5</sub>

PM<sub>2.5</sub> was continuously monitored and 5 minute averages logged. The 5 minute average data was then transformed to 1 hour averages for reporting.

PM<sub>2.5</sub> (1 hour average) mass rate of emission statistics for the reporting period are given in Table 12. A plot of PM<sub>2.5</sub> (1 hour average) mass rate of emission for the reporting period is presented in Figure 8.

**Table 12: PM<sub>2.5</sub> Mass Rate Percentiles (1 Hour Average)**

Station	PM <sub>2.5</sub> Mass Rate (kg/h) (1-Hour Average)						
	Maximum	99 <sup>th</sup>	98 <sup>th</sup>	95 <sup>th</sup>	90 <sup>th</sup>	75 <sup>th</sup>	50 <sup>th</sup>
Eastern	0.26	0.21	0.19	0.16	0.14	0.11	0.04
Western	0.27	0.24	0.21	0.17	0.15	0.11	0.05



*Figure 8: PM<sub>2.5</sub> Mass Rate (1 Hour Average)*




### 7.2.2 PM<sub>10</sub>

PM<sub>10</sub> was continuously monitored and 5-minute averages logged. The 5 minute average data was then transformed to 1 hour averages for reporting.

PM<sub>10</sub> (1 hour average) mass rate of emission statistics for the reporting period are given in Table 13. A plot of PM<sub>10</sub> (1 hour average) mass rate of emission for the reporting period is presented in Figure 9.

**Table 13: PM<sub>10</sub> Mass Rate Percentiles (1 Hour Average)**

Station	PM <sub>10</sub> Mass Rate (kg/h) (1-Hour Average)						
	Maximum	99 <sup>th</sup>	98 <sup>th</sup>	95 <sup>th</sup>	90 <sup>th</sup>	75 <sup>th</sup>	50 <sup>th</sup>
Eastern	0.45	0.33	0.30	0.25	0.21	0.16	0.06
Western	0.53	0.36	0.30	0.24	0.20	0.15	0.06



*Figure 9: PM<sub>10</sub> Mass Rate (1 Hour Average)*




### 7.2.3 Carbon Monoxide

Carbon monoxide (1 hour average) mass rate of emission statistics for the reporting period are given in Table 14. A plot of carbon monoxide (1 hour average) mass rate for the reporting period is presented in Figure 10.

**Table 14: Carbon Monoxide Mass Rate Percentiles (1 Hour Average)**

Station	Carbon Monoxide Mass Rate (kg/h) (1-Hour Average)						
	Maximum	99 <sup>th</sup>	98 <sup>th</sup>	95 <sup>th</sup>	90 <sup>th</sup>	75 <sup>th</sup>	50 <sup>th</sup>
Eastern	28	25	23	20	14	10	7.0
Western	33	29	26	20	17	13	9.0



*Figure 10: Carbon Monoxide Mass Rate (1 Hour Average)*




## 7.2.4 Oxides of Nitrogen

### 7.2.4.1 Nitric Oxide

Nitric oxide (1-hour average) mass rate of emission statistics for the reporting period are given in Table 15. A plot of nitric oxide (1-hour average) mass rate for the reporting period is presented in Figure 11.

**Table 15: Nitric Oxide Mass Rate Percentiles (1 Hour Average)**

Station	Nitric Oxide Concentration (ppm) (1-Hour Average)						
	Maximum	99 <sup>th</sup>	98 <sup>th</sup>	95 <sup>th</sup>	90 <sup>th</sup>	75 <sup>th</sup>	50 <sup>th</sup>
Eastern	4.9	4.3	4.1	3.5	2.9	2.3	1.3
Western	13	10	9.5	7.4	6.3	5.0	3.1



*Figure 11: Nitric Oxide Mass Rate (1 Hour Average)*



### 7.2.4.2 Nitrogen Dioxide

Nitrogen dioxide (1 hour average) mass rate of emission statistics for the reporting period are given in Table 16. A plot of nitrogen dioxide (1 hour average) mass rate for the reporting period is presented in Figure 12.

**Table 16: Nitrogen Dioxide Mass Rate Percentiles (1 Hour Average)**

Station	Nitrogen Dioxide Mass Rate (kg/h) (1-Hour Average)						
	Maximum	99 <sup>th</sup>	98 <sup>th</sup>	95 <sup>th</sup>	90 <sup>th</sup>	75 <sup>th</sup>	50 <sup>th</sup>
Eastern	0.4	0.4	0.3	0.3	0.3	0.2	0.1
Western	1.1	0.9	0.9	0.8	0.7	0.6	0.3




Figure 12: Nitrogen Dioxide Mass Rate (1 Hour Average)



## 7.2.5 Stack Velocity

The stack velocity (1 hour average) plot for the reporting period is presented in Figure 13.




Figure 13: Stack Velocity (1 Hour Average)



### 7.3 Data Validation and Exception

Data contained in the report has been validated against performance and calibration requirements for each instrument. Data during maintenance and calibration periods has been removed from the validated data sets. Tables 17 and 18 list the data exceptions for the eastern and western ventilation stacks respectively. Data during automatic calibrations of the gaseous atmospheric contaminants has also been removed from the data sets.

**Table 17: Data Exceptions - Eastern Ventilation Stack: May 2009**

Eastern Ventilation Stack			
Start	End	Parameter	Reason
5/05/2009 11:50	5/05/2009 13:00	NO, NO <sub>2</sub> , NO <sub>x</sub> , CO	Maintenance/calibration
6/05/2009 10:30	6/05/2009 13:20	PM <sub>10</sub> , PM <sub>2.5</sub>	Maintenance/calibration
6/05/2009 10:40	6/05/2009 11:10	CO	Maintenance/calibration
25/05/2009 12:55	25/05/2009 13:40	NO, NO <sub>2</sub> , NO <sub>x</sub>	Maintenance/calibration
25/05/2009 12:55	25/05/2009 13:45	CO	Maintenance/calibration
27/05/2009 12:30	27/05/2009 13:05	NO, NO <sub>2</sub> , NO <sub>x</sub>	Maintenance/calibration

**Table 18: Data Exceptions - Western Ventilation Stack: May 2009**

Western Ventilation Stack			
Start	End	Parameter	Reason
5/05/2009 13:20	5/05/2009 14:10	NO, NO <sub>2</sub> , NO <sub>x</sub> , CO	Maintenance/calibration
6/05/2009 13:25	6/05/2009 14:05	PM <sub>2.5</sub>	Maintenance/calibration
6/05/2009 13:30	6/05/2009 14:05	PM <sub>10</sub>	Maintenance/calibration
6/05/2009 13:30	6/05/2009 14:00	CO	Maintenance/calibration
6/05/2009 21:35	6/05/2009 22:05	PM <sub>2.5</sub>	Unrealistic data
8/05/2009 11:00	8/05/2009 11:45	PM <sub>2.5</sub>	Maintenance/calibration
8/05/2009 11:00	8/05/2009 11:50	PM <sub>10</sub>	Maintenance/calibration
11/05/2009 11:50	11/05/2009 12:25	PM <sub>2.5</sub>	Maintenance/calibration
14/05/2009 16:10	14/05/2009 16:45	CO	Maintenance/calibration
21/05/2009 15:45	21/05/2009 16:15	NO, NO <sub>2</sub> , NO <sub>x</sub>	Maintenance/calibration
29/05/2009 10:55	29/05/2009 12:00	NO, NO <sub>2</sub> , NO <sub>x</sub> , CO	Maintenance/calibration



## **8.0 VENTILATION STACK EMISSION MONITORING PERIOD: 01/06/2009 – 30/06/2009**

### **8.1 Data Capture**

Data capture is defined as the number of valid data periods collected divided by the number of available data periods. Valid data excludes periods where the instrument is unavailable due to calibration and maintenance and excludes periods where the data has been rejected due to quality assurance/data validation procedures.

The data capture statistics for the reporting period 1<sup>st</sup> June to 30<sup>th</sup> June, 2009 are shown in Table 19. Averages were only collected for those periods where the 5 minute data constituted 75% data capture.

Section 8.3 provides further information on the reasons for invalid data periods.

**Table 19: Data Capture Statistics - 1 Hour Averages**

<b>Parameter</b>	<b>Station</b>	<b>Collected Periods</b>	<b>Available Periods</b>	<b>Data Capture</b>
PM <sub>2.5</sub>	Eastern	717	720	99.6%
	Western	718	720	99.7%
PM <sub>10</sub>	Eastern	716	720	99.4%
	Western	719	720	99.9%
NO, NO <sub>2</sub>	Eastern	681	720	94.6%
	Western	652	720	90.6%
CO	Eastern	685	720	95.1%
	Western	689	720	95.7%



## 8.2 Results


### 8.2.1 PM<sub>2.5</sub>

PM<sub>2.5</sub> was continuously monitored and 5-minute averages logged. The 5-minute average data was then transformed to 1-hour averages for reporting.

PM<sub>2.5</sub> (1-hour average) mass rate of emission statistics for the reporting period are given in Table 20. A plot of PM<sub>2.5</sub> (1-hour average) mass rate of emission for the reporting period is presented in Figure 14.

**Table 20: PM<sub>2.5</sub> Mass Rate Percentiles (1 Hour Average)**

Station	PM <sub>2.5</sub> Mass Rate (kg/h) (1-Hour Average)						
	Maximum	99 <sup>th</sup>	98 <sup>th</sup>	95 <sup>th</sup>	90 <sup>th</sup>	75 <sup>th</sup>	50 <sup>th</sup>
Eastern	0.33	0.18	0.17	0.15	0.13	0.10	0.04
Western	0.45	0.23	0.22	0.17	0.14	0.10	0.04



*Figure 14: PM<sub>2.5</sub> Mass Rate (1 Hour Average)*




### 8.2.2 PM<sub>10</sub>

PM<sub>10</sub> was continuously monitored and 5 minute averages logged. The 5 minute average data was then transformed to 1-hour averages for reporting.

PM<sub>10</sub> (1 hour average) mass rate of emission statistics for the reporting period are given in Table 21. A plot of PM<sub>10</sub> (1 hour average) mass rate of emission for the reporting period is presented in Figure 15.

**Table 21: PM<sub>10</sub> Mass Rate Percentiles (1 Hour Average)**

Station	PM <sub>10</sub> Mass Rate (kg/h) (1-Hour Average)						
	Maximum	99 <sup>th</sup>	98 <sup>th</sup>	95 <sup>th</sup>	90 <sup>th</sup>	75 <sup>th</sup>	50 <sup>th</sup>
Eastern	0.43	0.29	0.27	0.24	0.19	0.14	0.05
Western	0.56	0.32	0.29	0.22	0.19	0.13	0.05



*Figure 15: PM<sub>10</sub> Mass Rate (1 Hour Average)*




### 8.2.3 Carbon Monoxide

Carbon monoxide (1 hour average) mass rate of emission statistics for the reporting period are given in Table 22. A plot of carbon monoxide (1 hour average) mass rate for the reporting period is presented in Figure 16.

**Table 22: Carbon Monoxide Mass Rate Percentiles (1 Hour Average)**

Station	Carbon Monoxide Mass Rate (kg/h) (1-Hour Average)						
	Maximum	99 <sup>th</sup>	98 <sup>th</sup>	95 <sup>th</sup>	90 <sup>th</sup>	75 <sup>th</sup>	50 <sup>th</sup>
Eastern	27	24	24	21	15	10	7.2
Western	31	29	27	22	16	12	8.9



*Figure 16: Carbon Monoxide Mass Rate (1 Hour Average)*




## 8.2.4 Oxides of Nitrogen

### 8.2.4.1 Nitric Oxide

Nitric oxide (1-hour average) mass rate of emission statistics for the reporting period are given in Table 23. A plot of nitric oxide (1-hour average) mass rate for the reporting period is presented in Figure 17.

**Table 23: Nitric Oxide Mass Rate Percentiles (1 Hour Average)**

Station	Nitric Oxide Concentration (ppm) (1-Hour Average)						
	Maximum	99 <sup>th</sup>	98 <sup>th</sup>	95 <sup>th</sup>	90 <sup>th</sup>	75 <sup>th</sup>	50 <sup>th</sup>
Eastern	4.8	4.1	3.9	3.5	2.9	2.3	1.2
Western	11	10	9.4	7.2	6.1	4.8	2.9



*Figure 17: Nitric Oxide Mass Rate (1 Hour Average)*




**8.2.4.2 Nitrogen Dioxide**

Nitrogen dioxide (1-hour average) mass rate of emission statistics for the reporting period are given in Table 24. A plot of nitrogen dioxide (1-hour average) mass rate for the reporting period is presented in Figure 18.

**Table 24: Nitrogen Dioxide Mass Rate Percentiles (1 Hour Average)**

Station	Nitrogen Dioxide Mass Rate (kg/h) (1-Hour Average)						
	Maximum	99 <sup>th</sup>	98 <sup>th</sup>	95 <sup>th</sup>	90 <sup>th</sup>	75 <sup>th</sup>	50 <sup>th</sup>
Eastern	0.5	0.4	0.4	0.3	0.3	0.2	0.1
Western	1.3	1.2	1.1	1.0	0.9	0.7	0.4



*Figure 18: Nitrogen Dioxide Mass Rate (1 Hour Average)*



## 8.2.5 Stack Velocity

The stack velocity (1 hour average) plot for the reporting period is presented in Figure 19.




Figure 19: Stack Velocity (1 Hour Average)



### 8.3 Data Validation and Exception

Data contained in the report has been validated against performance and calibration requirements for each instrument. Data during maintenance and calibration periods has been removed from the validated data sets. Tables 25 and 26 list the data exceptions for the eastern and western ventilation stacks respectively. Data during automatic calibrations of the gaseous atmospheric contaminants has also been removed from the data sets.

**Table 25: Data Exceptions - Eastern Ventilation Stack: June 2009**

Eastern Ventilation Stack			
Start	End	Parameter	Reason
2/06/2009 16:20	2/06/2009 16:50	NO, NO <sub>2</sub> , NO <sub>x</sub>	Maintenance/calibration
12/06/2009 11:40	12/06/2009 12:15	NO, NO <sub>2</sub> , NO <sub>x</sub>	Maintenance/calibration
16/06/2009 12:50	16/06/2009 12:50	All parameters	Data logger error
17/06/2009 7:10	17/06/2009 7:10	All parameters	Data logger error
23/06/2009 13:15	23/06/2009 13:35	NO, NO <sub>2</sub> , NO <sub>x</sub>	Maintenance/calibration
23/06/2009 13:25	23/06/2009 14:00	PM <sub>10</sub> , PM <sub>2.5</sub>	Maintenance/calibration

**Table 26: Data Exceptions - Western Ventilation Stack: June 2009**

Western Ventilation Stack			
Start	End	Parameter	Reason
2/06/2009 0:30	3/06/2009 14:10	NO, NO <sub>2</sub> , NO <sub>x</sub>	Instrument out of service
3/06/2009 14:10	3/06/2009 15:20	NO, NO <sub>2</sub> , NO <sub>x</sub>	Maintenance/calibration
15/06/2009 13:15	15/06/2009 13:40	CO	Maintenance/calibration
23/06/2009 14:00	23/06/2009 14:35	PM <sub>10</sub> , PM <sub>2.5</sub>	Maintenance/calibration
29/06/2009 12:00	29/06/2009 12:35	PM <sub>2.5</sub>	Maintenance/calibration
30/06/2009 9:20	30/06/2009 13:45	NO, NO <sub>2</sub> , NO <sub>x</sub>	Maintenance/calibration
30/06/2009 9:20	30/06/2009 14:00	PM <sub>10</sub> , PM <sub>2.5</sub>	Maintenance/calibration



## 9.0 DISCUSSION

### 9.1 Comparison with Licence Limits

EastLink emissions to air from the road tunnel ventilation stacks DP1 and DP2 are subject to the licence requirements contained in Environment Protection Authority (Victoria) Waste Discharge Licence No. EA 63607.

The maximum measured 1 hour average mass rate for each parameter is compared with the applicable licence limit in Table 27.

**Table 27: Maximum (1 Hour Average) Mass Rate (01/04/2009 - 30/06/2009)**

Discharge Point No.	Discharge Description	Compound	Mass Rate ((kg/h)	Licence Limit (kg/h)
1	Western ventilation stack	PM <sub>2.5</sub>	0.45	2.4
		PM <sub>10</sub>	0.84	2.6
		NO <sub>2</sub>	1.3	3.98
		CO	33	112
2	Eastern ventilation stack	PM <sub>2.5</sub>	0.39	2.4
		PM <sub>10</sub>	0.52	2.6
		NO <sub>2</sub>	0.71	3.98
		CO	31	112

There were no exceedences of the licence limits for DP1 and DP2 during the reporting period.

Data capture statistics for 2009 year to date (01/01/2009 – 30/06/2009) are presented in Table 28.

**Table 28: Data Capture Year to Date**

Station	NO, NO <sub>2</sub>	CO	PM <sub>2.5</sub>	PM <sub>10</sub>
Eastern	96.0	97.3	93.3	86.8
Western	96.0	96.7	76.8	99.8



## Report Signature Page

Mark Tulau  
Senior Environmental Scientist

Frank Fler  
Principal Environmental Engineer

MT/FF/SLH

A.B.N. 64 006 107 857

z:\awn works in progress\draft reports\097613024 007 r rev 0 transfield services.doc



# **APPENDIX A**

## **Limitations**



## **LIMITATIONS**

This Document has been provided by Golder Associates Pty Ltd ("Golder") subject to the following limitations:

This Document has been prepared for the particular purpose outlined in Golder's proposal and no responsibility is accepted for the use of this Document, in whole or in part, in other contexts or for any other purpose.

The scope and the period of Golder's Services are as described in Golder's proposal, and are subject to restrictions and limitations. Golder did not perform a complete assessment of all possible conditions or circumstances that may exist at the site referenced in the Document. If a service is not expressly indicated, do not assume it has been provided. If a matter is not addressed, do not assume that any determination has been made by Golder in regards to it.

Conditions may exist which were not detected given the limited nature of the enquiry Golder was retained to undertake with respect to the site. Variations in conditions may occur between assessment locations, and there may be special conditions pertaining to the site which have not been revealed by the investigation and which have not therefore been taken into account in the Document. Accordingly, additional studies and actions may be required.

In addition, it is recognised that the passage of time affects the information and assessment provided in this Document. Golder's opinions are based upon information that existed at the time the information is collected. It is understood that the Services provided allowed Golder to form no more than an opinion of the actual conditions of the site at the time the site was visited and cannot be used to assess the effect of any subsequent changes in the quality of the site, or its surroundings, or any laws or regulations.

Any assessments, designs, and advice provided in this Document are based on the conditions indicated from published sources and the investigation described. No warranty is included, either express or implied, that the actual conditions will conform exactly to the assessments contained in this Document.

Where data supplied by the client or other external sources, including previous site investigation data, have been used, it has been assumed that the information is correct unless otherwise stated. No responsibility is accepted by Golder for incomplete or inaccurate data supplied by others.

Golder may have retained subconsultants affiliated with Golder to provide Services for the benefit of Golder. To the maximum extent allowed by law, the Client acknowledges and agrees it will not have any direct legal recourse to, and waives any claim, demand, or cause of action against, Golder's affiliated companies, and their employees, officers and directors.


This Document is provided for sole use by the Client and is confidential to it and its professional advisers. No responsibility whatsoever for the contents of this Document will be accepted to any person other than the Client. Any use which a third party makes of this Document, or any reliance on or decisions to be made based on it, is the responsibility of such third parties. Golder accepts no responsibility for damages, if any, suffered by any third party as a result of decisions made or actions based on this Document.

Golder Associates Pty Ltd GAP Form No. LEG04 RL1

At Golder Associates we strive to be the most respected global group of companies specialising in ground engineering and environmental services. Employee owned since our formation in 1960, we have created a unique culture with pride in ownership, resulting in long-term organisational stability. Golder professionals take the time to build an understanding of client needs and of the specific environments in which they operate. We continue to expand our technical capabilities and have experienced steady growth with employees now operating from offices located throughout Africa, Asia, Australasia, Europe, North America and South America.

Africa	+ 27 11 254 4800
Asia	+ 852 2562 3658
Australasia	+ 61 3 8862 3500
Europe	+ 356 21 42 30 20
North America	+ 1 800 275 3281
South America	+ 55 21 3095 9500

[solutions@golder.com](mailto:solutions@golder.com)  
[www.golder.com](http://www.golder.com)



**Golder Associates Pty Ltd**  
**Level 3, 50 Burwood Road**  
**Hawthorn Victoria 3122**  
**Australia**  
**T: +61 3 8862 3500**

